

Lancaster County Water & Sewer District
Data Sampled through EPA Unregulated Contaminant Monitoring Rule (PFAS)

Compound	FINAL MCL	Entry Point of Distribution System					
		6/17/2020	6/17/2020	3/3/2025	6/2/2025	9/3/2025	12/2/2025
USEPA Method		537.1	533	533	533	533	533
PFOA	4.0 ppt	2.6	3.1	<MRL	<MRL	<MRL	<MRL
PFOS	4.0 ppt	2.6	3.3	<MRL	<MRL	<MRL	<MRL
PFHxS	10 ppt	N/A	N/A	<MRL	<MRL	<MRL	<MRL
PFNA	10 ppt	N/A	N/A	<MRL	<MRL	<MRL	<MRL
HFPO-DA (commonly known as GenX Chemicals)	10 ppt	N/A	N/A	<MRL	<MRL	<MRL	<MRL
Mixtures containing two or more of PFHxS, PFNA, HFPO-DA, and PFBS	1 (unitless) Hazard Index	N/A	N/A	No Exceedance	No Exceedance	No Exceedance	No Exceedance

MRL - Maximum Reporting Limit

N/A - Data was Not Available (not requested)