

Lancaster County Water & Sewer District
Data Sampled through EPA Unregulated Contaminant Monitoring Rule (PFAS)

		Entry Point of Distribution System					There will be one (1) more set of data sampled and reported for the 2025 calendar year
Compound	FINAL MCL	6/17/2020	6/17/2020	3/3/2025	6/2/2025	9/3/2025	
USEPA Method		537.1	533	533	533	533	
PFOA	4.0 ppt	2.6	3.1	<MRL	<MRL	<MRL	
PFOS	4.0 ppt	2.6	3.3	<MRL	<MRL	<MRL	
PFHxS	10 ppt	N/A	N/A	<MRL	<MRL	<MRL	
PFNA	10 ppt	N/A	N/A	<MRL	<MRL	<MRL	
HFPO-DA (commonly known as GenX Chemicals)	10 ppt	N/A	N/A	<MRL	<MRL	<MRL	
Mixtures containing two or more of PFHxS, PFNA, HFPO-DA, and PFBS	1 (unitless) Hazard Index	N/A	N/A	No Exceedance	No Exceedance	No Exceedance	

MRL - Maximum Reporting Limit

N/A - Data was Not Available (not requested)