

Lancaster County Water & Sewer District  
Data Sampled through EPA Unregulated Contaminant Monitoring Rule (PFAS)

Entry Point of Distribution System

Compound	FINAL MCL	6/17/2020	6/17/2020	3/3/2025	There will be three (3) more sets of data sampled and reported for the 2025 calendar year
USEPA Method		537.1	533	533	
PFOA	4.0 ppt	2.6	3.1	<MRL	
PFOS	4.0 ppt	2.6	3.3	<MRL	
PFHxS	10 ppt	N/A	N/A	<MRL	
PFNA	10 ppt	N/A	N/A	<MRL	
HFPO-DA (commonly known as GenX Chemicals)	10 ppt	N/A	N/A	<MRL	
Mixtures containing two or more of PFHxS, PFNA, HFPO-DA, and PFBS	1 (unitless) Hazard Index	N/A	N/A	No Exceedance	

MRL - Maximum Reporting Limit

N/A - Data was Not Available (not requested)